

## **3370 Sixth Avenue – Façade Program Q and A – 7-22-2025**

### **General**

Q1: Do we have to use the bid sheet and itemize the scopes of work?

A: Yes, you must use the complete BID packet available on our website and on the NYS Contract Reporter. You are required to itemize the specific scopes of work you want to be considered for. If you'd prefer to be considered only for a lump sum bid (one total price covering all scopes of work), you can do that—but you must include a written explanation stating that intention. Please note that if we decide to award only part of the project to a vendor, we'll need itemized pricing to accurately deduct that portion from the full bid.

Q2. What lead-safe practices are required?

A. Contractors are responsible for identifying and addressing all environmental concerns, including compliance with lead-safe practices. They are expected to demonstrate professional judgment and follow all applicable regulations and guidelines.

Q3. Will prevailing wages be required?

A. Prevailing wages are not required.

### **Specific Questions and Answers for 3370 Sixth Avenue**

Q4: Are Techno posts required?

A: No, Techno posts are an option in lieu of frost wall. Plans are provided for both applications.

Q5: Is there an additional landing beside where the ramp meets the building?

A: Yes, per ADA requirements, landing must be provided at the 30' mark. This landing will begin after the 1/12 ramp at 30' and be followed by a 1/20 graded sidewalk. Detailed Plans are provided. SEE most recent plans for exacting specifications on ENTIRE PROJECT!